



Wastewater Treatment Facility

2605 Summit Rd * Baileys Harbor, WI 54202

Phone (920) 839-2037

e-mail: bhww@baileysharborwi.gov

WDNR Lab #415016910 / DATCP Lab # 105-505

8/29/23

On 8/29/23 there was a SSO (sanitary sewer overflow). We discovered an issue with the air relief manhole on Summit Rd. approximately 450 feet west of Hwy 57. The air relief valve malfunctioned and released sewage into the manhole. The manhole filled and some sewage leaked out into the ditch before it was noticed. As soon as possible, the manhole was pumped out and the valve closed. A septage hauler was called in to assist with cleanup of the surrounding area. Then lime was applied to disinfect the area. Repairs were made to the valve, and it was put back into operation. Approximately 100-200 gallons were estimated to have been released.

Sincerely,

Don Prust
Plant Manager