

**CITY OF  
ECHO, OREGON**

**AMENDMENT TO THE 2015 WASTEWATER FACILITIES PLAN UPDATE**

**October 2018**



**ANDERSON PERRY & ASSOCIATES, INC.**

**La Grande, Redmond, and Hermiston, Oregon  
Walla Walla, Washington**

# Table of Contents

---

<b>Introduction .....</b>	<b>1</b>
<b>Background .....</b>	<b>1</b>
<b>Option 3A - Phase 1 New Alternative Description.....</b>	<b>1</b>
<b>Option 3A - Phase 1 Proposed Improvements .....</b>	<b>2</b>
Summary of Estimated Costs (2018 Dollars) .....	2
<b>Option 3A - Phase 2 Alternative Description .....</b>	<b>3</b>
<b>Option 3A - Phase 2 Proposed Improvements .....</b>	<b>4</b>
Summary of Estimated Costs (2018 Dollars) .....	4

## **FIGURES**

- Figure 1 Option 3A Phase 1 - Fountain Evaporation and Stanfield Discharge Water Balance
- Figure 2 Option 3A Phase 1 - Fountain Evaporation and Stanfield Discharge Preliminary Cost Estimate
- Figure 3 Option 3A Phase 2 - Fountain Evaporation and Irrigation Discharge Water Balance
- Figure 4 Option 3A Phase 2 - Fountain Evaporation and Irrigation Discharge Preliminary Cost Estimate

## **APPENDIX**

- Potential Water and Wastewater Peak Day Demands by Month

## Introduction

The City of Echo, Oregon's 2015 Wastewater Facilities Plan Update (WWFP Update) recommended improvements to the City's collection, treatment, and disposal systems. The City has pursued implementation of the recommended improvements but is experiencing difficulty obtaining appropriate land for the recommended storage lagoon. The inability to acquire land is preventing them from meeting the time constraints of their Oregon Department of Environmental Quality issued Mutual Agreement and Order. Failure to meet the stipulated dates has placed the City at risk of fines and other enforcement actions for not complying with their National Pollutant Discharge Elimination System (NPDES) Permit. To eliminate the issue of land acquisition, an alternative disposal method has been developed.

Additionally, the City has received a proposal for the Northgate Development on land north of the City that may create wastewater flows well beyond the projected growth based on population presented in the WWFP Update. If this development moves forward, it would have a significant impact on any selected wastewater treatment and disposal approach. To address this potential impact to the City's plan, a two-phase option is presented, with the first phase addressing the base projected growth and the second phase for implementation if the Northgate Development proceeds.

## Background

The WWFP Update noted that collection system improvements are needed to the City's single lift station and pressure sewer line leading to the wastewater treatment plant (WWTP). The improvements would increase pumping flow rates, correct system control deficiencies, and replace outdated emergency and backup systems. A preliminary design of these improvements has been completed.

The WWFP Update also outlined WWTP improvements associated with influent metering; replacing/reconstructing lagoon valving, piping, and inlets; removal of sludge and debris; and restoration of the access road and bridge.

The current method for effluent disposal is evaporation during the summer and surface water discharge of treated and disinfected effluent during the winter (November 1 to April 30). The City is also allowed to distribute the reclaimed water on land for dissipation by evapotranspiration and controlled seepage using sound irrigation practices. The compliance issues of the system are related to the location of the City's outfall, which has not provided adequate mixing of the effluent in the Umatilla River, and the inability of the treatment lagoons to consistently and effectively produce effluent that meets the treatment limits stated in the City's NPDES Permit. Faced with likely revisions of regulations governing the disposal of effluent to the Umatilla River, the City decided that future effluent disposal will not include surface water discharge.

## Option 3A - Phase 1 New Alternative Description

The proposed Phase 1 disposal method is based on increasing evaporation in the City's lagoon system to eliminate current effluent flows and minimize future effluent flows. Flows that exceed the evaporation rate would be pumped via a proposed pump station and forcemain to the City of Stanfield for further treatment and disposal. This could be accomplished by installing a new pump in the existing pump building and piping from the building to the canal, along the canal under Interstate 84 (I-84), then along

I-84 to a manhole near the Pilot Truck Stop. A 7.5 horsepower (Hp) centrifugal pump with a 4-inch diameter pipeline is anticipated to be used, with a maximum pumping rate of 100 gallons per minute (gpm). To accomplish this transfer, the Cities of Echo and Stanfield have prepared an intergovernmental agreement (IGA) that set flow criteria and payment rates for accepting the effluent.

Increasing evaporation at the City's lagoon could be achieved by installing a floating fountain system that sprays water from the pond into the air over the pond. The water droplets increase the surface area of water in contact with air, resulting in an increase in the total amount of evaporation. Data on an evaporative system such as this are somewhat limited, so a conservative approach to design was used. For example, sprinkler irrigation loss information suggests a 15 percent evaporation loss rate could be achieved; however, a 5 percent loss rate was used for planning.

As the City of Echo experiences growth and increased wastewater flows, there will be periods when evaporation and the available storage capacity will be exceeded. Using an IGA, these excess flows would be pumped to the City of Stanfield via a new transfer pump station and forcemain to the nearest Stanfield collection system manhole.

The attached water balance presents projected wastewater flows for the year 2034 with no adjustments for infiltration and inflow reductions (see Figure 1). This balance is based on the fountains operating during the evaporation months of March through October with a pumping rate of 800 gpm. Monthly evaporation rates vary based on pan evaporation data. At these projected 2034 influent flows, approximately 1.6 million gallons (MG) of effluent would be discharged to the Stanfield system in a typical year.

### Option 3A - Phase 1 Proposed Improvements

It is proposed that collection system, WWTP, and effluent disposal improvements be completed as outlined in Chapter 6 of the WWFP Update with the following modifications:

1. Start with Option 3 with its proposed pump station and pressure main to the City of Stanfield collection system manhole as shown on Figure 5-12 of the WWFP Update.
2. Add the fountain evaporation system of Option 2 without the proposed new 2-acre storage lagoon. See Figure 5-9 of the WWFP Update.

The costs for these proposed Phase 1 effluent disposal improvements are itemized on Figure 2 herein. Construction costs are estimated at \$965,000 with a net present worth of \$1,202,000 (in 2018 dollars) when including 20 years of increased operational costs. A summary of the complete project costs including collection, treatment, and effluent disposal is shown below.

### Summary of Estimated Costs (2018 Dollars)

Collection System <sup>1</sup>	\$ 822,000
WWTP Function-Based Improvements <sup>1</sup>	\$ 776,000
Phase 1 Effluent Disposal	\$ 965,000
<b>Total Project Cost</b>	<b>\$2,563,000</b>

<sup>1</sup> WWFP Update estimate in 2015 dollars inflated at 5 percent per year.

### Option 3A - Phase 2 Alternative Description

With the addition of Northgate Development as currently proposed, the City's wastewater flows would more than double the 2034 projected population design criteria. The treatment capacity of the existing lagoon system the City needs for the 20-year planning period, and the combined City needs with the Northgate Development, are shown below.

	Treatment Capacity <sup>1</sup>	Future City Needs	Future City Needs with Northgate Development <sup>2</sup>
Average Annual Flow (MGD)	0.075	0.058	0.138
Average BOD Load (PPD)	177	124	291

Notes:

<sup>1</sup> Current facility is permitted for 0.12 MGD, but treatment capacity is limited based on a minimum detention time of 90 days.

<sup>2</sup> BOD loadings for the Northgate Development are based on a BOD concentration of 250 milligrams per liter.

BOD = Biochemical Oxygen Demand

MGD = Million gallons per day

PPD = Pounds per day

The current treatment facility is a facultative lagoon system that would not have enough treatment capacity to meet the needs of the Northgate Development. Additional aeration could provide sufficient oxygen to meet the treatment needs of the development. Approximately 5 Hp of aeration is needed to meet the oxygen demand. This could be added to the existing lagoons using floating aspirating aerators.

Discharge to the City of Stanfield at these higher flows would exceed the allowable limits in the IGA. Additionally, effluent disposal at the necessary volume would be cost-prohibitive at the IGA charge rate per 1,000 gallons. For these reasons, an alternative disposal approach is needed. It is assumed that continued discharge to the Umatilla River is not to be considered for the reasons noted in the WWFP Update. Assuming discharge to the Umatilla River is not a consideration, it is proposed that the City provide a new storage lagoon coupled with a reuse irrigation system for effluent disposal. Flows exceeding the available evaporation rates would be reclaimed for irrigation of crops, and discharge to the City of Stanfield would be discontinued except for backup disposal. If continued discharge to the Umatilla River is to be considered, a new WWFP should be completed that fully reevaluates all alternatives for treatment and disposal of the City's wastewater based on modified design criteria that include the Northgate Development.

A water balance for a storage and irrigation system is presented on Figure 3 herein. This system uses fountain evaporation at the WWTP to minimize effluent flows to a storage lagoon. The storage lagoon would provide 6 feet of effective storage depth for irrigation of 24.2 MG of reclaimed water. This could provide irrigation water for approximately 21.2 acres of alfalfa or supplement irrigation of a larger crop in combination with an existing water right.

### Option 3A - Phase 2 Proposed Improvements

The Phase 2 improvements would be constructed after the Phase 1 improvements discussed earlier, if the Northgate Development (or something similar) occurs (see the Appendix for estimated flows). Therefore, the collection system, treatment plant, and Stanfield disposal improvements would already have been completed. Phase 2 effluent storage and reuse improvements would include the following:

1. A second transmission pipeline would be constructed from the Phase 1 pump station to a new 8-acre storage lagoon located in the area of the Northgate Development.
2. An irrigation pump station and 22-acre irrigation system would be constructed on land near the storage lagoon to facilitate effluent reuse on crops for beneficial use.

The Phase 2 storage lagoon and irrigation improvements are similar to Option 1 shown on Figure 5-6 of the WWFP Update.

The costs for the Phase 2 effluent storage and reuse improvements are itemized on Figure 4 herein. Construction costs are estimated at \$2,026,000 with a net present worth of \$2,228,000 (in 2018 dollars) when including 20 years of increased operational costs. A summary of the complete project costs including collection, treatment, and effluent disposal is shown below.

#### Summary of Estimated Costs (2018 Dollars)

Collection System <sup>1</sup>	\$822,000
WWTP Function-Based Improvements <sup>1</sup>	\$776,000
Phase 1 Effluent Disposal	\$965,000
Phase 2 Effluent Disposal	\$2,026,000
<b>Total Project Cost</b>	<b>\$4,689,000</b>

<sup>1</sup> WWFP Update estimate in 2015 dollars inflated at 5 percent per year.

The proposed Phase 1 system improvements were reviewed with the City on July 6, 2017, and have been identified as the preferred alternative to pursue for implementation. Upon approval of this Amendment to the WWFP Update, funding would be secured, design documents would be completed, and environmental clearances would be obtained. The estimated bid date for the construction contract would be April 2019. It is estimated that construction would be completed prior to April 2020.

## FIGURES

---

**OPTION 3A PHASE 1 - FOUNTAIN EVAPORATION AND STANFIELD DISCHARGE WATER BALANCE  
2034 PROJECTED POPULATION**

Month	Influent <sup>1</sup> (MG)	Precipitation <sup>2</sup>		Evaporation <sup>3</sup>		Seepage <sup>4</sup> (MG)	Fountain Evaporation <sup>5</sup> (MG)	Discharge to Stanfield <sup>6</sup> (MG)	Storage Volume (+/-) (MG)	Cumulative Storage Volume (MG)	Lagoon Depth <sup>7</sup> (ft)
		(in)	(MG)	(in)	(MG)						
January	1.66	1.17	0.19	0.00	0.00	0.22	0.00	0.36	1.27	4.00	5.08
February	1.72	0.71	0.11	0.00	0.00	0.20	0.00	0.36	1.27	5.27	5.74
March	2.62	0.85	0.14	2.41	0.39	0.22	0.71	0.36	1.08	6.35	6.30
April	2.29	0.73	0.12	3.80	0.61	0.22	0.86	0.36	0.36	6.72	6.49
May	2.02	0.81	0.13	5.54	0.89	0.22	1.43	0.00	-0.39	6.32	6.29
June	1.57	0.74	0.12	6.77	1.08	0.22	1.73	0.00	-1.34	4.98	5.59
July	1.24	0.12	0.02	7.92	1.27	0.22	1.78	0.00	-2.01	2.96	4.54
August	1.14	0.16	0.03	6.76	1.08	0.22	1.79	0.00	-1.93	1.03	3.54
September	1.08	0.32	0.05	4.42	0.71	0.22	1.04	0.00	-0.83	0.19	3.10
October	1.20	0.82	0.13	2.78	0.45	0.22	0.71	0.15	-0.19	0.00	3.00
November	1.33	0.86	0.14	0.00	0.00	0.22	0.00	0.00	1.25	1.25	3.65
December	1.50	1.30	0.21	0.00	0.00	0.22	0.00	0.00	1.48	2.73	4.42
<b>TOTALS</b>	<b>19.37</b>	<b>8.59</b>	<b>1.38</b>	<b>40.40</b>	<b>6.47</b>	<b>2.63</b>	<b>10.05</b>	<b>1.59</b>	<b>0.00</b>		

	Acres	Square Feet	MG
Cell A Area	1.6	69,696	1.82
Cell B Area	2.2	95,832	2.51
Cell C Area	2.1	91,476	2.39
<b>Total</b>	<b>5.9</b>	<b>257,004</b>	<b>6.73</b>

Yellow shading = Maximum storage  
Blue shading = Minimum storage

**Notes:**

1. Influent. Influent flows are based on average monthly flow from January 2009 to December 2013. Data obtained from Discharge Monitoring Reports. Influent flows were calculated using the design population of 828.
2. Precipitation. Utilized precipitation on record with the Western Regional Climate Center (WRCC) for the Hermiston 2NW weather station from 1999 to 2014. Mean rainfall used for each month.
3. Evaporation. Utilized pan evaporation data obtained from the WRCC for the Hermiston 2S station, with a pan coefficient of 0.70.
4. Seepage. Existing lagoon seepage assumed to be 0.045 inch per day.
5. Fountain Evaporation. Based on a pump rate of 800 gallons per minute and estimating a 5 percent water loss.
6. Discharge to Stanfield. Discharge to Stanfield is balanced not to exceed the maximum operating depth of the lagoons.
7. Lagoon Depth. The minimum operating depth is estimated to be 3.0 feet and the maximum operating depth is 6.5 feet.

**CITY OF ECHO, OREGON**  
**AMENDMENT TO THE 2015 WASTEWATER FACILITIES PLAN UPDATE**  
**OPTION 3A PHASE 1**  
**FOUNTAIN EVAPORATION AND STANFIELD DISCHARGE**  
**PRELIMINARY COST ESTIMATE**  
**(YEAR 2018 COSTS)**

NO.	DESCRIPTION	UNIT	ESTIMATED QUANTITY	UNIT PRICE	TOTAL PRICE
1	Mobilization	LS	All Req'd	\$ 45,600	\$ 45,600
2	Traffic Control/Project Safety	LS	All Req'd	12,000	12,000
3	Fountains and Appurtenances	LS	All Req'd	79,000	79,000
4	Pump Station to Stanfield	LS	All Req'd	173,000	173,000
5	Piping	LF	4,200	42	176,400
6	Canal Crossing	LS	All Req'd	35,000	35,000
7	Surface Restoration	LS	All Req'd	13,000	13,000
8	Highway Bore and Crossing	LS	All Req'd	95,000	95,000
9	Miscellaneous Work	LS	All Req'd	23,000	23,000
<b>Total Estimated Construction Cost</b>					<b>\$ 652,000</b>
Contingency (15%)					98,000
Design Engineering, Administration, Legal, and Construction Engineering (20%)					130,000
Environmental Report					40,000
Cultural Resource Report					15,000
Permitting					15,000
Pipeline Easements					15,000
<b>TOTAL ESTIMATED OPTION 3A PHASE 1 PROJECT COST</b>					<b>\$ 965,000</b>

**PRESENT WORTH ANALYSIS (2018 DOLLARS)**

Item	Description	Annual Cost
<b><u>ADDITIONAL ANNUAL OPERATION, MAINTENANCE, AND REPLACEMENT (OM&amp;R)</u></b>		
1	Labor	\$ 5,250
2	Supplies, Parts, Maintenance, and Repairs	3,100
3	Replacement	1,500
4	Stanfield Charges for 1.6 Million Gallons of Influent (\$2.25/1,000 Gallons)	6,000
5	Electrical Cost (Pond Fountain and Transfer Pump)	3,100
<b>Total OM&amp;R</b>		<b>\$ 18,950</b>
Present Worth Operation and Maintenance Cost (5%, 20 years)		237,000
<b>Total Present Worth (2018 Dollars)</b>		<b>\$ 1,202,000</b>

OPTION 3A PHASE 2 - FOUNTAIN EVAPORATION AND IRRIGATION DISCHARGE WATER BALANCE  
2034 PROJECTED POPULATION WITH NORTHGATE DEVELOPMENT

Month	Treatment Cells												Storage Lagoon									
	Influent <sup>1</sup> (MG)	Precipitation <sup>2</sup>		Evaporation <sup>3</sup>		Seepage <sup>4</sup> (MG)	Fountain Evaporation <sup>5</sup> (MG)	Discharge to Stanfield <sup>6</sup> (MG)	Storage Lagoon Transfer (MG)	Storage Volume (+/-) (MG)	Storage Volume (MG)	Treatment Cell Depth <sup>7</sup> (ft)	Precipitation <sup>2</sup>		Evaporation <sup>3</sup>		Seepage <sup>4</sup> (MG)	Irrigation Crop: <i>Alfalfa</i> Acreage: 21.2		Storage Volume (+/-) (MG)	Storage Lagoon Volume (MG)	Storage Lagoon Depth <sup>8</sup> (ft)
		(in)	(MG)	(in)	(MG)								(in)	(MG)	(in)	(MG)		(in)	(MG)			
January	4.14	1.17	0.19	0.00	0.00	0.22	0.00	0.00	2.65	1.46	3.77	4.96	1.17	0.24	0.00	0.00	0.00		0.00	2.89	9.68	6.90
February	3.96	0.71	0.11	0.00	0.00	0.20	0.00	0.00	2.65	1.22	4.99	5.60	0.71	0.15	0.00	0.00	0.00		0.00	2.80	12.48	8.03
March	5.10	0.85	0.14	2.41	0.39	0.22	0.71	0.00	2.66	1.26	6.25	6.25	0.85	0.18	2.41	0.50	0.00		0.00	2.34	14.82	8.97
April	4.69	0.73	0.12	3.80	0.61	0.22	0.86	0.00	2.65	0.47	6.73	6.50	0.73	0.15	3.80	0.79	0.00	3.41	1.96	0.05	14.87	8.99
May	4.50	0.81	0.13	5.54	0.89	0.22	1.43	0.00	2.48	-0.39	6.33	6.29	0.81	0.17	5.54	1.15	0.00	5.44	3.13	-1.63	13.24	8.33
June	3.97	0.74	0.12	6.77	1.08	0.22	1.73	0.00	2.48	-1.42	4.91	5.55	0.74	0.15	6.77	1.40	0.00	7.41	4.27	-3.03	10.21	7.11
July	3.72	0.12	0.02	7.92	1.27	0.22	1.78	0.00	2.48	-2.01	2.89	4.51	0.12	0.02	7.92	1.64	0.00	10.29	5.93	-5.06	5.15	5.07
August	3.62	0.16	0.03	6.76	1.08	0.22	1.79	0.00	2.48	-1.93	0.96	3.50	0.16	0.03	6.76	1.40	0.00	8.65	4.98	-3.87	1.28	3.52
September	3.48	0.32	0.05	4.42	0.71	0.22	1.04	0.00	2.48	-0.91	0.04	3.02	0.32	0.07	4.42	0.92	0.00	5.05	2.91	-1.28	0.00	3.00
October	3.68	0.82	0.13	2.78	0.45	0.22	0.71	0.00	2.48	-0.04	0.00	3.00	0.82	0.17	2.78	0.57	0.00	1.79	1.03	1.04	1.04	3.42
November	3.73	0.86	0.14	0.00	0.00	0.22	0.00	0.00	2.65	1.00	1.00	3.52	0.86	0.18	0.00	0.00	0.00		0.00	2.83	3.87	4.56
December	3.98	1.30	0.21	0.00	0.00	0.22	0.00	0.00	2.65	1.31	2.31	4.20	1.30	0.27	0.00	0.00	0.00		0.00	2.92	6.79	5.74
TOTALS	48.57	8.59	1.38	40.40	6.47	2.63	10.05	0.00	30.79	0.00			8.59	1.78	40.40	8.36	0.00	42.05	24.20	0.00		

	Effective Storage			
	Acres	Depth (ft)	Square Feet	MG
Cell A Area	1.6	3.5	69,696	1.82
Cell B Area	2.2	3.5	95,832	2.51
Cell C Area	2.1	3.5	91,476	2.39
Subtotal	5.9		257,004	6.73
Storage Lagoon	7.62	6	331,927	14.90
Total	13.5		588,931	21.63

Orange shading = Irrigation area  
Yellow shading = Maximum storage  
Blue shading = Minimum storage

Notes:

1. Influent. Influent flows are based on average monthly flow from January 2009 to December 2013. Data obtained from Discharge Monitoring Reports. Influent flows were calculated using the design population of 828 plus 0.08 MGD flow for the Northgate Development.
2. Precipitation. Utilized precipitation on record with the Western Regional Climate Center (WRCC) for the Hermiston 2NW weather station from 1999 to 2014. Mean rainfall used for each month.
3. Evaporation. Utilized pan evaporation data obtained from the WRCC for the Hermiston 2S station, with a pan coefficient of 0.70.
4. Seepage. Existing lagoon seepage assumed to be 0.045 inch per day. Storage lagoon seepage assumed to be 0.
5. Fountain Evaporation. Based on a pump rate of 800 gallons per minute and estimating a 5 percent water loss.
6. Discharge to Stanfield. No discharge to Stanfield for Phase 2; backup disposal only.
7. Treatment Cell Depth. The minimum operating depth is estimated to be 3.0 feet and the maximum operating depth is 6.5 feet.
8. Storage Lagoon Depth. The minimum operating depth is estimated to be 3.0 feet and the maximum operating depth is 9 feet, for an effective operating storage depth of 6 feet.

**CITY OF ECHO, OREGON**  
**AMENDMENT TO THE 2015 WASTEWATER FACILITIES PLAN UPDATE**  
**OPTION 3A PHASE 2**  
**FOUNTAIN EVAPORATION AND IRRIGATION DISCHARGE**  
**PRELIMINARY COST ESTIMATE**  
**(YEAR 2018 COSTS)**

NO.	DESCRIPTION	UNIT	ESTIMATED QUANTITY	UNIT PRICE	TOTAL PRICE
1	Mobilization	LS	All Req'd	\$ 89,200	\$ 89,200
2	Traffic Control/Project Safety	LS	All Req'd	12,000	12,000
3	Pump Station Additions	LS	All Req'd	42,000	42,000
4	Piping	LF	6,900	42	289,800
5	Clearing and Grubbing	Acre	8	1,050	8,400
6	Earthwork	CY	23,100	4	92,400
7	Pond Liner	SF	190,000	0.80	152,000
8	Riprap	CY	4,300	42	180,600
9	Fencing	LF	2,400	11	26,400
10	Base Rock	CY	700	21	14,700
11	Irrigation Pump Station	LS	All Req'd	120,000	120,000
12	Irrigation Piping	LF	2,500	40	100,000
13	Irrigation System (22 acres)	LS	All Req'd	60,000	60,000
14	Canal Crossing	LS	All Req'd	35,000	35,000
15	Surface Restoration	LS	All Req'd	20,000	20,000
16	Highway Bore	LS	All Req'd	10,500	10,500
17	Miscellaneous Work	LS	All Req'd	22,000	22,000

**Total Estimated Construction Cost \$ 1,275,000**

Contingency (15%) 191,000

Design Engineering, Administration, Legal, and Construction Engineering (20%) 255,000

Land Acquisition for Storage Pond and Irrigation 200,000

Environmental Report 40,000

Cultural Resource Report 15,000

Permitting 15,000

Pipeline Easements 15,000

Cultural Resource Monitoring 20,000

**TOTAL ESTIMATED OPTION 3A PHASE 2 PROJECT COST \$ 2,026,000**

**PRESENT WORTH ANALYSIS (2018 DOLLARS)**

Item	Description	Annual Cost
<u>ANNUAL OPERATION, MAINTENANCE, AND REPLACEMENT (OM&amp;R)</u>		
1	Labor	\$ 5,250
2	Supplies, Parts, Maintenance, and Repairs	3,100
3	Replacement	1,800
4	Stanfield Charges for 0 Million Gallons of Influent (\$3.75/1,000 Gallons)	-
5	Electrical Cost (Pond Fountain, Transfer Pump, and Irrigation)	6,000
<b>Total OM&amp;R</b>		<b>\$ 16,150</b>
Present Worth Operation and Maintenance Cost (5%, 20 years)		202,000
<b>Total Present Worth (2018 Dollars)</b>		<b>\$ 2,228,000</b>




CITY OF  
**ECHO, OREGON**  
 AMENDMENT TO THE 2015 WASTEWATER FACILITIES PLAN UPDATE  
**OPTION 3A PHASE 2 - FOUNTAIN**  
**EVAPORATION AND IRRIGATION DISCHARGE**  
**PRELIMINARY COST ESTIMATE**

**FIGURE**  
**4**

## **APPENDIX**


---

**Potential Water and Wastewater Peak Day Demands by Month**  
**PLANNING LEVEL ESTIMATE**  
**Echo Hill Development**  
K & L Madison, LLC  
December 13, 2016




Type of Establishment	Establishment Details	Water Demand <sup>1</sup>		Wastewater Demand <sup>2</sup>	
		Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	Gallons Per Day (gpd)/Unit	Establishment Total (gpd)
NOVEMBER - FEBRUARY					
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000
	2 People per Room (Avg.)				
	50 People Using Swimming Pool <sup>4</sup>		500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		180	10 gpd/100 ft <sup>2</sup>	180
Mushroom Farm	Industrial Waste <sup>5</sup>	259,200 gpd	259,200	25,920 gpd	25,920
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250
Establishments <sup>6</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900
NOVEMBER-FEBRUARY PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		290,000		60,000	
MARCH					
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000
	100,000 ft <sup>2</sup> Landscaping	121 gpd/1,000 ft <sup>2 9</sup>	12,100	--	--
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000
	2 People per Room (Avg.)				
	50 People Using Swimming Pool <sup>4</sup>		500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		180	10 gpd/100 ft <sup>2</sup>	180
	20,000 ft <sup>2</sup> Landscaping	121 gpd/1,000 ft <sup>2 9</sup>	2,420	--	--
Amphitheater	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	121 gpd/1,000 ft <sup>2 9</sup>	9,731	--	--
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	121 gpd/1,000 ft <sup>2 9</sup>	3,497	--	--
MARCH PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		320,000		60,000	
APRIL					
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000
	100,000 ft <sup>2</sup> Landscaping	216 gpd/1,000 ft <sup>2 9</sup>	21,600	--	--
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000
	2 People per Room (Avg.)				
	50 People Using Swimming Pool <sup>4</sup>		500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		180	10 gpd/100 ft <sup>2</sup>	180
	20,000 ft <sup>2</sup> Landscaping	216 gpd/1,000 ft <sup>2 9</sup>	4,320	--	--
Amphitheater	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	216 gpd/1,000 ft <sup>2 9</sup>	17,372	--	--
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	216 gpd/1,000 ft <sup>2 9</sup>	6,242	--	--
APRIL PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		340,000		60,000	

**Potential Water and Wastewater Peak Day Demands by Month**  
**PLANNING LEVEL ESTIMATE**  
**Echo Hill Development**  
K & L Madison, LLC  
December 13, 2016




Type of Establishment	Establishment Details	Water Demand <sup>1</sup>		Wastewater Demand <sup>2</sup>		
		Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	
MAY						
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850	
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000	
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000	
	100,000 ft <sup>2</sup> Landscaping	291 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	29,100	--	--	
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000	
	2 People per Room (Avg.)					
	50 People Using Swimming Pool <sup>4</sup>		10 gpd/person	500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		10 gpd/100 ft <sup>2</sup>	180	10 gpd/100 ft <sup>2</sup>	180
	20,000 ft <sup>2</sup> Landscaping	291 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	5,820	--	--	
Amphitheater	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	291 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	23,404	--	--	
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920	
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250	
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900	
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	291 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	8,410	--	--	
MAY PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		360,000		60,000		
JUNE						
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850	
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000	
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000	
	100,000 ft <sup>2</sup> Landscaping	373 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	37,300	--	--	
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000	
	2 People per Room (Avg.)					
	50 People Using Swimming Pool <sup>4</sup>		10 gpd/person	500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		10 gpd/100 ft <sup>2</sup>	180	10 gpd/100 ft <sup>2</sup>	180
	20,000 ft <sup>2</sup> Landscaping	373 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	7,460	--	--	
Amphitheater	10,000 Seat	5 gpd/seat	50,000	5 gpd/seat	50,000	
	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	373 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	29,999	--	--	
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920	
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250	
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900	
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	373 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	10,780	--	--	
JUNE PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		430,000		110,000		

**Potential Water and Wastewater Peak Day Demands by Month**  
**PLANNING LEVEL ESTIMATE**  
**Echo Hill Development**  
K & L Madison, LLC  
December 13, 2016




Type of Establishment	Establishment Details	Water Demand <sup>1</sup>		Wastewater Demand <sup>2</sup>		
		Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	
JULY						
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850	
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000	
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000	
	100,000 ft <sup>2</sup> Landscaping	419 gpd/1,000 ft <sup>2 9</sup>	41,900	--	--	
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000	
	2 People per Room (Avg.)					
	50 People Using Swimming Pool <sup>4</sup>		10 gpd/person	500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		10 gpd/100 ft <sup>2</sup>	180	10 gpd/100 ft <sup>2</sup>	180
	20,000 ft <sup>2</sup> Landscaping	419 gpd/1,000 ft <sup>2 9</sup>	8,380	--	--	
Amphitheater	10,000 Seat	5 gpd/seat	50,000	5 gpd/seat	50,000	
	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	419 gpd/1,000 ft <sup>2 9</sup>	33,698	--	--	
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920	
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250	
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900	
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	419 gpd/1,000 ft <sup>2 9</sup>	12,109	--	--	
JULY PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		440,000		110,000		
AUGUST						
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850	
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000	
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000	
	100,000 ft <sup>2</sup> Landscaping	372 gpd/1,000 ft <sup>2 9</sup>	37,200	--	--	
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000	
	2 People per Room (Avg.)					
	50 People Using Swimming Pool <sup>4</sup>		10 gpd/person	500	10 gpd/person	500
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		10 gpd/100 ft <sup>2</sup>	180	10 gpd/100 ft <sup>2</sup>	180
	20,000 ft <sup>2</sup> Landscaping	372 gpd/1,000 ft <sup>2 9</sup>	7,440	--	--	
Amphitheater	10,000 Seat	5 gpd/seat	50,000	5 gpd/seat	50,000	
	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	372 gpd/1,000 ft <sup>2 9</sup>	29,918	--	--	
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920	
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250	
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900	
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	372 gpd/1,000 ft <sup>2 9</sup>	10,751	--	--	
AUGUST PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		430,000		110,000		

**Potential Water and Wastewater Peak Day Demands by Month**  
**PLANNING LEVEL ESTIMATE**  
**Echo Hill Development**  
K & L Madison, LLC  
December 13, 2016



Type of Establishment	Establishment Details	Water Demand <sup>1</sup>		Wastewater Demand <sup>2</sup>		
		Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	
SEPTEMBER						
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850	
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000	
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000	
	100,000 ft <sup>2</sup> Landscaping	246 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	24,600	--	--	
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000	
	2 People per Room (Avg.)		10 gpd/person	500	10 gpd/person	500
	50 People Using Swimming Pool <sup>4</sup>		10 gpd/100 ft <sup>2</sup>	180	10 gpd/100 ft <sup>2</sup>	180
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		246 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	4,920	--	--
Amphitheater	10,000 Seat	5 gpd/seat	50,000	5 gpd/seat	50,000	
	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	246 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	19,785	--	--	
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920	
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250	
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900	
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	246 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	7,109	--	--	
SEPTEMBER PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		400,000		110,000		
OCTOBER						
Gas Station & Convenience Store	285 Vehicles Served <sup>3</sup>	10 gpd/vehicle served	2,850	10 gpd/vehicle served	2,850	
Laundry Mat	8 Machines 40 Washings per Day	50 gpd/ washing	2,000	500 gpd/machine	4,000	
RV Park	100 Spaces	125 gpd/space	12,500	100 gpd/space	10,000	
	100,000 ft <sup>2</sup> Landscaping	100 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	10,000	--	--	
Hotel	100 Rooms	50 gpd/ person/room	10,000	120 gpd/room	12,000	
	2 People per Room (Avg.)		10 gpd/person	500	10 gpd/person	500
	50 People Using Swimming Pool <sup>4</sup>		10 gpd/100 ft <sup>2</sup>	180	10 gpd/100 ft <sup>2</sup>	180
	1,800 ft <sup>2</sup> Swimming Pool Maintenance		100 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	2,000	--	--
Amphitheater	80,425 ft <sup>2</sup> Landscaping <sup>5</sup>	100 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	8,043	--	--	
Mushroom Farm	Industrial Waste <sup>6</sup>	259,200 gpd	259,200	25,920 gpd	25,920	
	150 Employees	15 gpd/person/shift	2,250	15 gpd/person/shift	2,250	
Establishments <sup>7</sup>	10 Additional Establishments 6 Employees per Industry	15 gpd/person/shift	900	15 gpd/person/shift	900	
Landscaping	280,900 ft <sup>2</sup> Landscaping <sup>8</sup>	100 gpd/1,000 ft <sup>2</sup> <sup>9</sup>	2,890	--	--	
OCTOBER PEAK DAY DEMAND SUBTOTAL (gpd) <sup>10</sup>		310,000		60,000		
AVERAGE PEAK DAY DEMAND TOTAL (gpd) <sup>10</sup>		350,000		80,000		
AVERAGE PEAK DAY DEMAND TOTAL (MGD) <sup>10</sup>		0.35		0.08		
AVERAGE PEAK DAY DEMAND TOTAL (gpm) <sup>10</sup>		243		56		
AVERAGE YEARLY DEMAND TOTAL (gallons/year) <sup>10</sup>		127,750,000		29,200,000		
AVERAGE YEARLY DEMAND TOTAL (million gallons/year) <sup>10</sup>		127.75		29.20		

**Potential Water and Wastewater Peak Day Demands by Month**  
**PLANNING LEVEL ESTIMATE**  
**Echo Hill Development**  
 K & L Madison, LLC  
 December 13, 2016



Type of Establishment	Establishment Details	Water Demand <sup>1</sup>		Wastewater Demand <sup>2</sup>	
		Gallons Per Day (gpd)/Unit	Establishment Total (gpd)	Gallons Per Day (gpd)/Unit	Establishment Total (gpd)
SUMMARY					
NOVEMBER - FEBRUARY	DOMESTIC DEMAND	Water = 0.03 MGD (10% of Total)		Wastewater = 0.03 MGD (50% of Total)	
	IRRIGATION DEMAND	Water = N/A		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (90% of Total)		Wastewater = 0.03 MGD (50% of Total)	
MARCH	DOMESTIC DEMAND	Water = 0.03 MGD (9% of Total)		Wastewater = 0.03 MGD (50% of Total)	
	IRRIGATION DEMAND	Water =0.03 MGD (9% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (81% of Total)		Wastewater = 0.03 MGD (50% of Total)	
APRIL	DOMESTIC DEMAND	Water = 0.03 MGD (9% of Total)		Wastewater = 0.03 MGD (50% of Total)	
	IRRIGATION DEMAND	Water =0.05 MGD (15% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (76% of Total)		Wastewater = 0.03 MGD (50% of Total)	
MAY	DOMESTIC DEMAND	Water = 0.03 MGD (8% of Total)		Wastewater = 0.03 MGD (50% of Total)	
	IRRIGATION DEMAND	Water =0.07 MGD (20% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (72% of Total)		Wastewater = 0.03 MGD (50% of Total)	
JUNE	DOMESTIC DEMAND	Water = 0.08 MGD (19% of Total)		Wastewater = 0.08 MGD (73% of Total)	
	IRRIGATION DEMAND	Water =0.09 MGD (21% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (60% of Total)		Wastewater = 0.03 MGD (27% of Total)	
JULY	DOMESTIC DEMAND	Water = 0.08 MGD (18% of Total)		Wastewater = 0.08 MGD (73% of Total)	
	IRRIGATION DEMAND	Water =0.10 MGD (23% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (59% of Total)		Wastewater = 0.03 MGD (27% of Total)	
AUGUST	DOMESTIC DEMAND	Water = 0.08 MGD (19% of Total)		Wastewater = 0.08 MGD (73% of Total)	
	IRRIGATION DEMAND	Water =0.09 MGD (21% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (60% of Total)		Wastewater = 0.03 MGD (27% of Total)	
SEPTEMBER	DOMESTIC DEMAND	Water = 0.08 MGD (20% of Total)		Wastewater = 0.08 MGD (73% of Total)	
	IRRIGATION DEMAND	Water =0.06 MGD (15% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (65% of Total)		Wastewater = 0.03 MGD (27% of Total)	
OCTOBER	DOMESTIC DEMAND	Water = 0.03 MGD (9% of Total)		Wastewater = 0.03 MGD (50% of Total)	
	IRRIGATION DEMAND	Water =0.03 MGD (9% of Total)		Wastewater = N/A	
	INDUSTRIAL DEMAND	Water = 0.26 MGD (82% of Total)		Wastewater = 0.03 MGD (50% of Total)	

<sup>1</sup>Water demand determined using the following publication: Water System Design Manual, December 2009, Table 5-2: Guide for Average Daily Nonresidential Water Demand.

<sup>2</sup>Wastewater demand determined using the following publication: OAR 340-071-0220 Onsite Wastewater Treatment Systems - Standard Subsurface Systems, Table 2: Quantities of Sewage Flows.

<sup>3</sup>Assume 15% of ODOT 2015 AADT (1900 AADT located 0.9 miles south of Umatilla-Stanfield Highway U.S. 395)

<sup>4</sup>Assume 25% of the average number of people staying at the hotel (~200 people/night) use the pool.

<sup>5</sup>Area is that of 1/4 of a 320' center pivot.

<sup>6</sup>Mushroom farm provided demands of 180 gal/min (water) and 18 gal/min (wastewater).

<sup>7</sup>Industrial waste is not anticipated at these undefined establishments.

<sup>8</sup>Assumes additional undefined landscaping is approximately 5% of the 132 acre site.

<sup>9</sup>The landscape demand per unit was calculated using nearby (Hermiston) historic precipitation, evaporation, and evapotranspiration data from AgriMet (<http://www.usbr.gov/pn/agrimet/chartkey.html>) and the Western Region Climate Center (<http://www.wrcc.dri.edu/cgi-bin/cliMAIN.pl?or3847>) to determine the monthly irrigation needs. 1" of rainfall/ft<sup>2</sup> = 0.63 gpd/ft<sup>2</sup>.

<sup>10</sup>The estimated demand is planning level and are to be taken as approximate. Actual demands will be refined as the site design progresses and establishments are secured.