



REEDSVILLE UTILITY DEPARTMENT

300 Mud Creek Rd
Reedsville, WI 54230
Phone: 920-754-4371

Email: dirpublicworks@reedsvillewi.gov
www.reedsvillewi.gov

Press Release

May 3rd, 2023

FOR IMMEDIATE RELEASE

Sanitary sewer overflow has occurred in the Village of Reedsville. The over flow occurred at 300 Mud Creek Road on May 1st, 2023 at 7:00am until May 2nd, 2023 at 2:00pm.

On May 1st, 2023, we noticed an abnormal wet spot in the grass around the Wastewater Treatment Plant. With concerns of the force mains from Manitowoc Street life station below, we contacted our contractor to dig up the wet spot. We found there was a blowhole in our storm sewer force main, which fills our storm pond. The blowhole has been repaired and everything is operating as it should.

The Wisconsin Department of Natural Resources has been notified. Pursuant to the requirements of NR210, this press release is being issued regarding this event.

Jason Maertz

Director of Public Works