

Town of Chazy
Annual Drinking Water Quality Report for 2025
Chazy Water District
P.O. Box 219
Chazy, NY, 12921
(Public Water Supply ID # NY0930113)

INTRODUCTION

To comply with State regulations, Chazy Water District annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Jon Higgins, Water Operator, at 518-565-7517 or the Clinton County Health Department Environmental Unit at 518-565-4870. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regular scheduled Town of Chazy board meetings. The meetings are held the second Wednesday of each month at 5:00 PM at the Chazy Town Hall.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately 690 people with 221 service connections in the Town of Chazy. The water system consists of three 600-foot deep drilled wells located in the town's well field at 47 Riley Drive. The water is pumped from the wells into a 200,000 gallon storage tank. The water is disinfected with sodium hypochlorite as it is transferred to the storage tank prior to distribution.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, total haloacetic acids, radiologicals, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Clinton County Health Department at 518-565-4870.

Table of Detected Contaminants: 2025

Contaminant	Violation Y/N	Date of Samples	Level Detected (average range)	Unit Measurement	MCLG	Regulatory Limit (MCL, T or AL)	Likely Source of Contamination	
Copper (1)	N	07/16/24	90 th = 0.13 R: ND – 0.18	mg/L	1.3	1.3 AL	Corrosion of household plumbing systems; Erosion of natural deposits; leaching	
Lead (2)	N	07/16/24	90 th = 0.0045 R: ND – 0.0121	mg/L	0	0.015 AL	Corrosion of household plumbing systems; Erosion of natural deposits	
Barium	N	09/04/24	102.0	ug/L	2000	2000	Naturally occurring	
Fluoride	N	09/04/24	0.2	mg/L	N/A	2.2		
Radium 226	N	05/28/24	1.24	pCi/L	N/A	MCL = 5	Erosion of natural deposits	
Radium 228	N	05/28/24	2.46	pCi/L	N/A	MCL = 5		
Nitrate	N	02/04/25	2.4	mg/L	10	MCL = 10	Runoff from fertilizer, naturally occurring	
m/p - Xylene	N	09/04/24	1.0	ug/L	N/A	MCL = 5	Naturally occurring	
STAGE 2 Disinfection by-products								
TTHM's (3) (Total Trihalomethanes) Location 1: Poirier's True Value Hardware (TV) Location 2: Waste Water Treatment Plant (WWTP)	N	Quarter: Date Q1: 01/07/25 Q2: 06/03/25 Q3: 09/08/25 Q4: 12/01/25 LRAA	TV 36.8 50.4 74.0 42.8 51.0	WWTP 51.8 73.1 87.2* 50.2 65.6	ug/L	N/A	80	By-product of drinking water disinfection
HAA5's (Total Haloacetic Acids) Location 1: Poirier's True Value Hardware (TV) Location 2: Waste Water Treatment Plant (WWTP)	N	Quarter: Date Q1: 01/07/25 Q2: 06/03/25 Q3: 09/08/25 Q4: 12/01/25 LRAA	TV 8.6 8.8 9.6 8.3 8.8	WWTP 13.0 14.8 14.2 10.1 13.0	ug/L	N/A	60	By-product of drinking water disinfection

Notes:

(1) The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case 10 samples were collected from our water system at many different locations around our Town and the 90th percentile value was the second highest value. The action level for copper was not exceeded at any of the sites tested. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer kidney damage. People with Wilson's disease should consult their personal doctor.

(2) The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any of the sites tested. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

(3) Two samples for TTHM's and HAA5's were taken each quarter. TTHM's: The MCL of 80 ug/L is based on a Locational Running Annual Average (LRAA) - the average of 4 samples collected each quarter for TTHM's and HAA5's. This level represents the highest locational running annual average. Stage 2 sampling compliance is determined by the LRAA. * Quarter 3 sampling for TTHM's was 87.2 ug/L. The LRAA was below the MCL (80 ug/L) at 65.6 ug/L.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/L): Corresponds to one part of liquid in one million parts of liquid (parts per million-ppm).

Micrograms per liter (ug/L): Corresponds to one part of liquid in one billion parts of liquid (parts per billion-ppb).

Picocuries per liter (pCi/L): A measure of radioactivity

WHAT DOES THIS INFORMATION MEAN?

During 2025, our system did not have any MCL violations. We have learned through all of our other testing that some contaminants have been detected, however, these contaminants were detected below the level allowed by the State.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

In 2025 our system was in compliance with all state required sampling and documentation. There was one precautionary Boil Water Order on 01/27/25 due to a water main break.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Chazy Water District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Jon Higgins at 518-565-7417. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by the following link: <https://tinyurl.com/2024LSLI> No lead or galvanized pipes were used in the construction of our water system.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The cost of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

Thank you,

Jon Higgins
Water Supervisor