

Oswego Solar Project

Address: 447 Co Rt 20, Oswego, NY 13126

Project Size: 3 megawatt (MW) alternating current (AC) (Enough to power 900 houses.)

Zoning District: R-3

Parcel Size: 78 acres

Limit of Disturbance: 22.4 acres

Point of Interconnection: Existing three-phase distribution line on County Route 20

Interconnection: Paloma substation, which serves the City and Town of Oswego and extends into portions of the towns of Hannibal, Ganby, Minetto, Scriba, and Volney

Topography: A nearly level site with very little grading required.

Flood Zones: The project is not located within any FEMA designated flood zones.

Wetlands and Waterbodies: The project avoids all federally and state regulated wetlands.

Agricultural Resources: The site is not located in an Agricultural District and is not used for agricultural purposes.

Threatened and Endangered Species or Habitats: Consultation with the U.S. Fish and Wildlife Service, the New York Department of Environmental Conservation, and New York Natural Heritage Program concluded that there would be no impact to threatened/endangered species or critical habitats.

Archaeological/Cultural Resources: The New York State Office of Parks, Recreation and Historic Preservation Office (SHPO) reviewed the site and concluded that no historic properties, including archaeological and/or historic resources, will be affected by this undertaking.

Contact Information:

Christopher Ross / cross@necenergy.com

RKC Development, LLC, 85 Broad St, 28th Floor, New York, NY 10004



Oswego Solar Site Plan



447 Co Rd 20, Oswego, NY 13026

ZONING DISTRICT SOLAR CODE REQUIREMENTS

	Requirement	Oswego Solar
Maximum Lot Coverage	30%	78.6%
Maximum Height	45'	10'-12'
Minimum Front Setback	50'	+660'
Minimum Side Setback	20'	45.2'-148.8'
Minimum Rear Setback	20'	82.3'