

Town of Bristol
Public Works
Cross Connection/ Inflow Inspection Report

Address _____

Name of Owner _____

New Meter # _____ New ROM # _____

Old Meter# _____ Old ROM # _____

New Meter reading _____ Old meter reading _____

Location of Meter _____

Any Problems with meter the customer needs to correct _____

Is double check installed at meter _____

Check all hose bibs for cross connections _____

Make sure all hose bibs have check valves _____

Is there a well and all plumbing separate from system _____

If there is a well do they have an operation permit from the utility _____

Sewer check

The sump pump can not be hooked up to sewer

Do they have a sump pump _____

If not where do their footing tiles drain to _____

Is there clear water flowing into the floor drains _____

Does the sump pump flow outside to surface ground _____

If not where is it hooked up to _____

Is there any quick connections to sewer for sump _____

Any repairs home owner needs to make _____

Home owners Signature _____ Phone number _____