

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which sha

### Number of Contaminants Required to be Tested

This table displays the number of contaminants that were required to be tested in the last five years. The CCR may contain up to five years worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown on the CCR. If testing is done less frequently, the results shown on the CCR are from the past five

Contaminant Group	# of Contaminant
Inorganic Contaminants	16
Disinfection Byproducts	1
Radioactive Contaminants	1
Unregulated Contaminants	4
Microbiological Contaminants	1
Volatile Organic Contaminants	21
Synthetic Organic Contaminants including Pesticides and Herbicides	23

### Inorganic Contaminants

Contaminant	MCL	MCLG	Level Found	Range	Sample Date (if Prior to 2006)	Violation	Typical Source of Contaminant
ARSENIC (ppb)	10	n/a	2	0-2	06/21/2005	NO	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)	2	2	.075	.058-.075	06/21/2005	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
COPPER (ppm)	AL=1.3	1.3	.8400	.0490-1.3000	08/09/2005	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
FLUORIDE (ppm)	4	4	1.3	.6-1.3	06/21/2005	NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
LEAD (ppb)	AL=15	0	3.40	.00-4.50	08/09/2005	NO	Corrosion of household plumbing systems; Erosion of natural deposits
SELENIUM (ppb)	50	50	2	0-2	06/21/2005	NO	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)	n/a	n/a	19.00	12.00-19.00	06/21/2005	NO	n/a

### Radioactive Contaminants

Contaminant	MCL	MCLG	Level Found	Range	Sample Date (if Prior to 2006)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	15	0	11.0	.9-11.0	03/19/2002	NO	Erosion of natural deposits