



Village of Kennard

Annual Water Quality Report For January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the Village of Kennard water system to provide safe drinking water.

Para Clientes Que Hablan Español: Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

For more information regarding this report, or to request a hard copy, contact:

MIKE ADAIR
402-677-3781

If you would like to observe the decision-making processes that affect drinking water quality, please attend the regularly scheduled meeting of the Village Board/City Council. If you would like to participate in the process, please contact the Village/City Clerk to arrange to be placed on the agenda of the meeting of the Village Board/City Council.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Source Water Assessment Availability:

The Nebraska Department of Water, Environment, and Energy (DWEE) has completed the Source Water Assessment. Included in the assessment are a Wellhead Protection Area map, potential contaminant source inventory, and source water protection information. To view the Source Water Assessment or for more information please contact the person named above on this report or the DWEE at 402-471-3376 or 402-471-9249 or go to <http://dwee.ne.gov>.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Sources of Drinking Water:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals

and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

The source of water used by Village of Kennard is purchased surface water. Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above.

Buyer Name	Seller Name
Village of Kennard	City Of Blair

Contaminants that may be present in source water include:

- * Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- * Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- * Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- * Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- * Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking Water Health Notes:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Village of Kennard is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact: MIKE ADAIR, 402-677-3781. Information on lead in drinking water, testing methods, and steps you can take to

minimize exposure is available at <http://www.epa.gov/safewater/lead>.

The Village of Kennard is required to test for the following contaminants: Coliform Bacteria, Antimony, Arsenic, Asbestos, Barium, Beryllium, Cadmium, Chromium, Copper, Cyanide, Fluoride, Lead, Mercury, Nickel, Nitrate, Nitrite, Selenium, Sodium, Thallium, Alachlor, Atrazine, Benzo(a)pyrene, Carbofuran, Chlordane, Dalapon, Di(2-ethylhexyl)adipate, Dibromochloropropane, Dinoseb, Di(2-ethylhexyl)-phthalate, Diquat, 2,4-D, Endothal, Endrin, Ethylene dibromide, Glyphosate, Heptachlor, Heptachlor epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Lindane, Methoxychlor, Oxamyl (Vydate), Pentachlorophenol, Picloram, Polychlorinated biphenyls, Simazine, Toxaphene, Dioxin, Silvex, Benzene, Carbon Tetrachloride, o-Dichlorobenzene, Para-Dichlorobenzene, 1,2-Dichloroethane, 1,1-Dichloroethylene, Cis-1,2-Dichloroethylene, Trans-1,2-Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene, Monochlorobenzene, 1,2,4-Trichlorobenzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, Vinyl Chloride, Styrene, Tetrachloroethylene, Toluene, Xylenes (total), Gross Alpha (minus Uranium & Radium 226), Radium 226 plus Radium 228, Sulfate, Chloroform, Bromodichloromethane, Chlorodibromomethane, Bromoform, Chlorobenzene, m-Dichlorobenzene, 1,1-Dichloropropane, 1,1-Dichloroethane, 1,1,2,2-Tetrachloroethane, 1,2-Dichloropropane, Chloromethane, Bromomethane, 1,2,3-Trichloropropane, 1,1,1,2-Tetrachloroethane, Chloroethane, 2,2-Dichloropropane, o-Chlorotoluene, p-Chlorotoluene, Bromobenzene, 1,3-Dichloropropene, Aldrin, Butachlor, Carbaryl, Dicamba, Dieldrin, 3-Hydroxycarbofuran, Methomyl, Metolachlor, Metribuzin.

How to Read the Water Quality Data Table:

The EPA and State Drinking Water Program establish the safe drinking water regulations that limit the amount of contaminants allowed in drinking water. The table shows the concentrations of detected substances in comparison to the regulatory limits. Substances not detected are not included in the table. The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be older than one year.

MCL (Maximum Contaminant Level) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

AL (Action Level) – The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow.

MRDL (Maximum Residual Disinfectant Level) – The highest level of a disinfectant allowed in drinking water.

N/A – Not applicable.

Units in the Table:

ND – Not detectable.

ppm (parts per million) – One ppm corresponds to 1 gallon of concentrate in 1 million gallons of water.

mg/L (milligrams per liter) – Equivalent to ppm.

ppb (parts per billion) – One ppb corresponds to 1 gallon of concentrate in 1 billion gallons of water.

ug/L (micrograms per liter) – Equivalent to ppb.

pCi/L (Picocuries per liter) – Radioactivity concentration unit.

RAA (Running Annual Average) – An ongoing annual average calculation of data from the most recent four quarters.

LRAA (Locational Running Annual Average) – An ongoing annual average calculation of data from the most recent four quarters at each sampling location.

90th Percentile – Represents the highest value found out of 90% of the samples taken in a representative group. If the 90th percentile is greater than the action level, it will trigger a treatment or other requirements that a water system must follow.

TT (Treatment Technique) – A required process intended to reduce the level of a contaminant in drinking water.

Microbiological	Highest Number of Positive Samples		MCL		MCLG	Likely Source of Contamination	Violations Present	
No Detected Results were Found in the Calendar Year of 2025								
Lead and Copper	Monitoring Period	90 th Percentile	Range	Unit	AL	Sites Over AL	Likely Source of Contamination	
COPPER, FREE	2019 - 2021	0.0518	0.0113 - 0.0666	ppm	1.3	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.	
LEAD	2019 - 2021	9.6	0 - 17.9	ppb	15	1	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.	
Disinfection Byproducts		Monitoring Period	Highest RAA	Range	Unit	MCL	MCLG	Likely Source of Contamination
TOTAL HALOACETIC ACIDS (HAA5)		1/1/2025 - 12/31/2025	12.4475	2.64 - 21.7	ppb	60	0	By-product of drinking water disinfection.
TTHM		7/1/2024 - 6/30/2025	51.95	38.4 - 66.8	ppb	80	0	By-product of drinking water disinfection.

During the 2025 calendar year, we had the below noted violation(s) of drinking water regulations.

Violation Type	Category	Analyte	Compliance Period
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	MON	LEAD & COPPER RULE	10/01/2024 - 01/29/2025

The Village of Kennard has taken the following actions to return to compliance with the Nebraska Safe Drinking Water Act:

Uncorrected Significant Deficiencies			
Date Identified	Facility	Category Code	Category Description
03/28/2024	WATER SYSTEM	2247	22-004 Item 7e - Failure to require cross-connection surveys

The Village of Kennard has taken the following actions to address the deficiencies listed above:

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2025 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination
ANTIMONY, TOTAL	7/14/2025	City Of Blair	0.503	0.503	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
ATRAZINE	7/8/2025	City Of Blair	0.166	0 - 0.166	ppb	3	3	Runoff from herbicide used on row crops
BARIUM	7/8/2025	City Of Blair	0.0205	0.0205	ppm	2	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
CARBON, TOTAL	10/14/2025	City Of Blair	4.2	2.06 - 4.2	ppm			Naturally present in the environment
CHROMIUM	7/8/2025	City Of Blair	1.84	1.84	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.
COMBINED RADIUM (-226 & -228)	7/26/2022	City Of Blair	0.361	0.361	pCi/L	5	0	Erosion of natural deposits
FLUORIDE	7/8/2025	City Of Blair	0.331	0.331	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge.
NITRATE-NITRITE	2/11/2025	City Of Blair	0.661	0.661	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Unregulated Water Quality Data	Collection Date	Water System	Highest Value	Range	Unit	Secondary MCL
ALKALINITY, CARBONATE	1/21/2025	City Of Blair	224	172 - 224	mg/L	
METOLACHLOR	7/8/2025	City Of Blair	0.174	0.11 - 0.174	ppb	
SULFATE	7/14/2025	City Of Blair	209	209	mg/L	250

During the 2025 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2025				

There are no additional required health effects notices.

There are no additional required health effects violation notices.

The Village of Kennard lead service line inventory has been prepared and can be accessed here: _____

Capacity Development & ECLs

Capacity Development:

Jessica L Johnson
Jessica.L.Johnson@nebraska.gov
402-471-0088

Emergency Contact Lists:

Natalia Yunge Ossenkop
Natalia.YungeOssenkop@nebraska.gov
402-471-2713

Drinking Water Program Contacts

NEBRASKA

Good Life. Great Resources.

DEPT. OF WATER, ENERGY, AND ENVIRONMENT

Field Rep: David Jundt
David.Jundt@nebraska.gov
402-750-0967
M&C: Mary Poe
Mary.Poe@Nebraska.gov
402-471-1003

Field Rep: Bret Gieselman
Bret.Gieselman@nebraska.gov
402-649-6243
M&C: Alexis Moss
Alexis.Moss@Nebraska.gov
402-471-0172

Supervisor Contacts

Field Services:
Andy Kahle
Andy.Kahle@nebraska.gov
402-471-0521

Monitoring & Compliance:
Taylor Benzel
Taylor.Benzel@nebraska.gov
402-471-0930

Field Rep: Bill Taylor
Bill.Taylor@nebraska.gov
308-763-8926
M&C: Mary Poe
Mary.Poe@Nebraska.gov
402-471-1003


Field Rep: Chris Brader
Chris.Brader@nebraska.gov
(402) 679-7214
M&C: Caitlin Faust
Caitlin.Faust@Nebraska.gov
402-471-1009

Field Rep: John Sauer
John.Sauer@nebraska.gov
308-530-4651
M&C: Liam Baker
Liam.Baker@Nebraska.gov
402-471-4228

Field Rep: Jeffrey Edmondson
Jeff.Edmondson@nebraska.gov
308-390-2071
M&C: Abby Schroeder
Abby.Schroeder@Nebraska.gov
402-471-1008

Field Rep: Eric Cox
Eric.Cox@nebraska.gov
402-432-4831
M&C: Abby Schroeder
Abby.Schroeder@Nebraska.gov
402-471-1008

Field Rep: VACANT
402-471-1079
M&C: Logan Morgaridge
Logan.Morgaridge@Nebraska.gov
402-471-1010



Training and Certification

Water Operator Certification:

Leena Lynch
Leena.Lynch@nebraska.gov
402-471-0523

Water Operator Training:

Greg Brekel
Greg.Brekel@nebraska.gov
308-530-3930