

Please Take the Chloride Reduction Survey
Jul 16, 2018

**If you havent turned in or taken the Chloride Reduction Survey here it is!
Please follow the link below.**

<https://www.surveymonkey.com/r/G53WHGB>

More Info:

CHLORIDES AND WATER SOFTENERS

FREQUENTLY ASKED QUESTIONS ABOUT CHLORIDE:

The Wisconsin Department of Natural Resources has reissued the Village's waste water discharge permit. The new permit requires lower limits on chlorides that the treatment plant discharges. Chlorides or salts are not something we can treat at our sewer plant therefore; we must concentrate on reducing chlorides in the water coming into the sewer plant, i.e. water softeners and road salts.

The Village is constantly trying to reduce the amount of road salt used on icy roads. Water softener usage, on the other hand, is entirely up to the residents.

If the Village is unsuccessful in reducing the amount of chlorides in the waste water, the alternatives are an increase in operational costs.

What is it?

Chloride is one of two components of sodium, also known as table salt or rock salt. When salt dissolves in water, it separates into sodium (Na⁺) ions and Chloride (Cl⁻) ions.

Where does Chloride come from?

Small amounts of Chloride come from soaps, detergents, and other cleaning products. Some also comes from commercial processes and road deicing operations. A significant amount of Chloride comes from self-regenerating water softeners.

Our Environment

Why should I care about Chloride?

Our freshwater streams and lakes contain low levels of naturally occurring salts, including chloride. These salts are essential to the aquatic organisms that live there. However, high concentrations of Chloride are harmful to aquatic plants and animals.

How does it get in the Environment?

From the water softener, Chloride is flushed into the sewer where it goes to the wastewater treatment plant. Treatment plants are designed to remove particles, like grit and sand, and to

biologically degrade organic waste, such as food and human waste. Once Chloride is dissolved in water it cannot be removed by settling, or biologically degraded by standard treatment processes. Chloride that comes to the Village of Paddock Lake treatment plant passes through the plant to the aquifer and eventually to Duck Creek.

Can treatment plants be modified to remove Chloride?

The technology to remove Chloride is available, but is very costly. It would involve microfiltration and reverse osmosis, which are the same treatment processes used to produce pure water used in laboratories. One community determined that it would cost about twenty cents to add a pound of Chloride at the water softener, and \$5.00 to remove it at the treatment plant. Households can use up to 100 lbs. of salt a month in their water softeners.

Is Potassium Chloride a better choice than Sodium Chloride for my water softener?

No. Although it consists of Potassium instead of Sodium, it still contains Chloride. There is no advantage to using Potassium Chloride as your softener salt in Wyocena. In some of the drier parts of the western U.S., crops are regularly irrigated with treated effluent wastewater. Certain crops are sensitive to sodium, and in those areas, they are promoting the use of Potassium Chloride over Sodium Chloride.

Hard Water

What makes hard water hard?

Rainwater that falls is “soft”. It does not contain any minerals. As it percolates through the soil, water dissolves minerals which can include calcium and magnesium. Water with substantial amounts of calcium and magnesium is referred to as “hard water”.

How do you measure hardness?

Hardness is measured in terms of grains per gallon (g/gal) or milligrams per liter (mg/l). If you were to evaporate one gallon of water that had a hardness of 5 g/gal, the residue would be equal to one-5-grain aspirin tablet. Laboratories often record hardness as mg/l or parts per million (ppm). One g/gal hardness is equal to 17.1 mg/l of hardness. In the example above, 5 g/gal equals 85.5 mg/l hardness. Water that is 10g/gal or more is considered very hard.

What is the problem with hard water?

The minerals in hard water can be deposited as scale on pipes and in hot water heaters. They also chemically interact with soaps and detergents and make them less efficient. For example, it takes 50% to 75% less detergent to clean laundry in soft water than hard water.

How hard is Wyocena’s water?

The Total hardness of (CAC03) of our water is 246 mg/l. Converted is 14.38 g/gal. Please follow this link to “size up” your softener <https://www.aquatell.com/pages/how-to-properly-size-a-water-softener>

Water Softeners

How is water Softened?

Home water softeners have two tanks: a mineral tank that contains resin in the form of small beads, and a brine tank which holds the sodium salt chloride (salt) solution. As water flows through the mineral tank, the hard minerals, magnesium (Mg^{++}) and calcium (Ca^{++}) ions, replace sodium (Na^{+}) ions on the resin. This process is called ion exchange. The water that flows out is considered "soft" because sodium ions do not build up on pipes as lime or interfere with detergents and soaps.

What is the Regeneration Cycle?

Eventually, the resin reaches its limit as to how much calcium and magnesium it can hold. At this point, the resin is flushed with a strong brine solution from the brine tank. Because of its high salt concentration, the brine washes off the calcium and magnesium and replaces them with sodium. The minerals and brine wash go down the drain and into the sewer system. New salt must be added regularly to the brine tank to replace the salt that is used to regenerate the resin. The regeneration cycle can be initiated by a timer or by demand. A timer regulated softener regenerates the resin after a fixed amount of time regardless of how much water is used. A demand initiated regeneration (DIR) softener either tracks the amount of water used or utilizes a hardness sensor to indicate the resin is near capacity and needs to be regenerated. A DIR softener is the more efficient softener in terms of salt and water usage.

The back wash phase removes dirt from the mineral tank.

Recharging the mineral tank with sodium from the brine solution displaces calcium and magnesium, which is washed down the drain.

The final phase rinses the mineral tank with fresh water and loads the brine tank so it is ready for the next cycle.

Road Salt

How much chloride comes from road de-icing?

Road salt used to de-ice streets is also a source of chloride.

The road salt dissolves and enters the ground water; this ground water enters the Village sanitary sewer collection system through small cracks and joints of the sewer pipes.

What Can I Do?

Check to see how your softener is calibrated. Some softeners are preset for the highest hardness setting at the factory. This setting may be as hard as 30 grains. Reset the hardness to 20 grains.

The Total hardness of (CAC03) of our water is 246 mg/l. Converted is 14.38 g/gal. Please follow this link to "size up" your softener <https://www.aquatell.com/pages/how-to-properly-size-a-water-softener>

Soften only water used inside the home. Do not treat the outside hose faucets.

Check the timer. When it was last adjusted? Many of us move into a house or purchase a water softener and never check it again. Children move out or other factors come into play that affects the amount of water we use. If your softener is regulated by a timer, you may be able to increase the interval between regeneration cycles without affecting the water quality. Increase the time by one day and see if there is any effect on dish washing and laundry during the next month.

If you are replacing your old softener, replace it with a softener that regenerates based on a meter or a sensor. The Benefits to you are a substantial cost savings from your salt and water usage reduction, with the added benefit that you are helping to protect our environment right here in the Village of Wyocena.

Discharge of softener

Under the State of Wisconsin plumbing code the by-pass water from a softener may be discharge to a clear water sump pump or to the surface of the ground provided a nuisance from the discharge water is not created.

Together the residents, Village Board and the Village Staff can avert the need to construct an expensive sewer treatment plant micro filter and prevent future increases to sewer user fees.